



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DW-7511CT0380**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	NTG Plastik Sanayi ve Ticaret A.S. Seyhli Mah.Ankara Cad.No:326 Kat:1-, TR-34906 Pendik-Istanbul
<b>Distributor</b> <i>Vertreiber</i>	NTG Plastik Sanayi ve Ticaret A.S. Seyhli Mah.Ankara Cad.No:326 Kat:1-, TR-34906 Pendik-Istanbul
<b>Product Category</b> <i>Produktart</i>	Material transition fittings: transition on PE-HD for water pipes (7511)
<b>Product description</b> <i>Produktbezeichnung</i>	transition on PE-HD for water pipes
<b>Model</b> <i>Modell</i>	PE-Brass Transition Adaptor
<b>Test reports</b> <i>Prüfberichte</i>	Laboratory control test: RA7002.230540.23 from 05.07.2023 (SKZ) Type testing: 129300/18 from 27.09.2018 (SKZ)
<b>Test basis</b> <i>Prüfgrundlagen</i>	DVGW GW 335-B4/(P) (01.04.2014) UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023) UBA KTW-BWGL (07.03.2022) DVGW W 270 (01.11.2007)

**Date of Expiry / File No.** 27.09.2028 / 23-0663-WNV  
**Ablaufdatum / Aktenzeichen**

12.09.2023 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

*P. Schmidt*



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
PE-Brass Transition Adaptor	Nominal diameter: 20 mm Max. operating pressure: 16 bar	
PE-Brass Transition Adaptor	Nominal diameter: 25 mm Max. operating pressure: 16 bar	
PE-Brass Transition Adaptor	Nominal diameter: 32 mm Max. operating pressure: 16 bar	
PE-Brass Transition Adaptor	Nominal diameter: 40 mm Max. operating pressure: 16 bar	
PE-Brass Transition Adaptor	Nominal diameter: 50 mm Max. operating pressure: 16 bar	
PE-Brass Transition Adaptor	Nominal diameter: 63 mm Max. operating pressure: 16 bar	

**certified Components****zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
HW-1002DN0432	Components from plastic, product group P1	PE100 / NTG Fittings/NTG Fittings	NTG Plastik Sanayi ve Ticaret A.S.

**Hints of Utilization / Remarks****Verwendungshinweise / Bemerkungen**

Connection: pipe socket made of PE-HD respectively female thread or male thread 1/2 " up to 2"

DVGW